Certificate of Conformity

Number CoC-16200171-01b
Project number 16200171

Issued by	:	NMi Certin B.V., Hugo de Grootplein 1 314 EG Dordrecht The Netherlands
Applicant	:	Iskra, d.d. Stegne 21 SI-1000 Ljubljana Slovenia
Submitted	:	**A meter embedding IEC 61000-4-30 Power Quality functions** Manufacturer : Iskra, d.d. Type : MC784 / iMC784
Characteristics	:	See page 2 and further
In accordance with	:	**IEC 61000-4-30 Ed. 3 (2015)** "Electromagnetic Compatibility (EMC) – Part 4-30: Testing and measurement techniques – Power quality measurement methods" **IEC 62586-2 Ed. 2 (2017)** "Power quality measurement in power supply systems - Part 2: Functional tests and uncertainty requirements"
Measurement class	:	IEC 61000-4-30 class A

The undersigned declares that the described product is tested according to the above mentioned standard and meet their requirements, based on a non-recurrent examination. The appertaining test data is presented in type evaluation report number NMi-16200171-01b, granted by NMi Certin B.V.

NMi Certin B.V.
6 November 2017

C. Oosterman
Head Certification Board

NMi Certin B.V.
Hugo de Grootplein 1
3314 EG Dordrecht
The Netherlands
T +31 (0)78 633 23 20
certin@nmi.nl
www.nmi.nl

This document is issued under the provision that no liability is accepted and that the applicant shall indemnify third-party liability.

Parties concerned can lodge objection against this decision, within six weeks after the date of submission, to the general manager of NMi Certin B.V. (see www.nmi.nl).

Reproduction of the complete document only is permitted.

INSPECTION
RvA I 122

101

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

Certificate of Conformity

IEC 61000-4-30 Power Quality functions tested
The following IEC 61000-4-30 measurement methods have been tested

Table 1 IEC 61000-4-30 Power Quality functions tested

IEC 62586-2 Clause	IEC 61000-4-30 parameter (clause)	IEC 61000-4-30 class	Comments
6.1	Power frequency (5.1)	**A**	50 Hz and 60 Hz
6.2	Magnitude of the supply voltage (5.2)	**A**	
6.3	Flicker (5.3)	**A**	IEC 61000-4-15 Class F1
6.4	Supply voltage interruptions, dips and swells (5.4 / 5.5)	**A**	50 Hz and 60 Hz
6.5	Supply voltage unbalance (5.7)	**A**	
6.6	Voltage harmonics (5.8)	**A**	
6.7	Voltage inter-harmonics (5.9)	**A**	
6.8	Mains signalling voltages on the voltage supply (5.10)	**A**	Method 1 + Method 2
6.9	Measurement of underdeviation and overdeviation parameters (Annex D)	**A**	
6.10	Flagging (4.7)	**A**	
6.11	Clock uncertainty (4.6)	**A**	
6.12	Variation of external influence quantities	**A**	Temperature: -10°C .. +55°C Power supply: 80 – 276 VAC 70 – 300 VDC
6.13	Rapid Voltage Changes (RVC) (5.11)	**A**	
6.14	Current Magnitude (5.13.2)	**A**	
6.15	Current Harmonics (5.13.4)	**A**	
6.16	Current Interharmonics (5.13.5)	**A**	
6.17	Current unbalance (5.13.6)	**A**	
8	Measurement uncertainty and operating uncertainty	**A**	

A : compliance with class A
S : compliance with class S
--- : Not implemented

The tests are performed in accordance with IEC 62586-2 edition 2 (2017).

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

Certificate of Conformity

Characteristics of the measuring instrument
In Table 2 the general characteristics of the measuring instrument are presented.

Table 2 General characteristics

U_{din}	230 V
I_{nom}	5 A (Nominal current used for testing)
f_{nom}	50 Hz and 60 Hz
Temperature	Rated range of operation: -10°C to +55°C
Power supply range	80 … 276 VAC 70 ... 300 VDC
Software version	FW : 1.08 (measuring software) TFT : 1.08 (display software) OS : 1.07 (system software - Linux)
Hardware version	A
Environmental application	Fixed (F), Indoor (I)

LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000